


ADDENDUM NO. 3
SULLIVAN WATER TREATMENT PLANT REHABILITATION PROJECT – PHASE 2
EQUIPMENT BUILDING & CLEARWELL REHAB
DWSRF PROJECT FS010412-01
NEEL SCHAFFER PROJECT NS.17174.000

October 24, 2023

1. Drawing C-2; Add the following note to the 2 doors at the entrance and exit from the Lab/Office and noted as Existing Door to Remain; "Replace Door Hardware with like materials and finish."
2. Change the date on Addendum from October 30, 2023, to October 23, 2023.
3. Drawing E-04R; Delete circuit 18 from the Panel Board Schedule RP-1.
4. Drawing E-13: Delete the symbol "LIT" at the chlorine scales and the callout for electrical circuit "RP-1, Cir. 18."
5. Drawing C-5, Key Note 3; Add the following to this note: "Reznor Model EGHB Industrial Suspended Unit Heater, or equal."
6. Drawing C-5, Key Note 8; Add the following to this note: "National Fan Company, Model XSA120-DD033V or equal." Delete the last sentence in this note and replace with the following; "Exhaust fans shall be fitted with gravity louvers."
7. Drawing C-5, Key Note 8; Add the following to this note: "Chlorine Room exhaust fan shall be provided with intake ducting to within 12-inches of the finished floor elevation."
8. Drawing C-5, Key Note 16; Add the following to this note; "Mitsubishi Model PUZ-A36NKA7, or equal."

END OF ADDENDUM 3


Phillip R. Guin, P.E.

